

SPCC PLAN CHECKLISTDate of Desk Review: 12/3/81

Time of Investigation \_\_\_\_\_

- 1) Facility Name Lancia Oil Company 1a) Owner: Lancia Oil Company  
 2) Location South River Street, Hacken- 1b) Operator: Same As Above  
sack, New Jersey. 1c) Telephone: 201-342-5454  
 3) Classification of facility: Storage. Types of Oil: #2 Fuel, Diesel  
 3.5) Is certified SPCC plan available: Yes. Fuel  
 4) Nearest navigable water: Hackensack  
River.  
 5) Spill history indicated (for previous 12 months): None.

- 6) Responsible official: Hugo Lance  
 7) Management official: Same As Above  
 8) P.E. certification: Yes. Charles Biggs #9486 Date: 10/29/81  
 9) Does plan consider: \_\_\_\_\_

- a. Prediction of potential spills Yes  
 b. Facility drainage..... Yes  
 c. Topo maps..... Yes  
 d. Containment of bulk storage.... Yes  
 e. Facility for transfer operation Yes  
 f. Proper security..... Yes  
 g. Inspection & records procedure Yes  
 h. Training..... Yes  
 9.5) Implementation Yes.  
 10) Does plan require construction of additional facilities? Yes.  
 If so, is it discussed in plan (including schedule) Yes.  
 Construction complete During 1982.  
 11) Storage capacity: (Total) 1,202,000 gal.  
 11a) Above grade 1,200,000 gal.  
 11b) Below grade 2,000 gal.  
 12) Number of hours facility is manned: 24 Hours.  
 13) NPDES Permit No. None.  
 14) Coast Guard Manual N/A  
 15) Operator's Comments: See attached letter.

General Appraisal: \_\_\_\_\_

Recommendation: Conduct an on-site inspection of Lancia Oil Company.Signature of Investigator: Christine HylemonDate: Dec 4, 1981

235223

